

試驗報告



報告編號: KV-18-07816

頁數: 1 OF 1

報告日期: 107年09月07日

委託單位: 無機善護宅有限公司
 地址: 高雄市前鎮區佛南街139號
 產品名稱: 金鎧甲 SJ 特殊金屬奈米防鏽封閉塗劑
 產品顏色: 淺藍色
 供應廠商: 無機善護宅有限公司
 送驗廠商: 無機善護宅有限公司
 收件日期: 107年07月24日
 試驗日期: 107年07月24日~107年09月07日

備註: 1. 以上資料由顧客提供(收件及試驗日期除外)
 2. 除非另有說明, 此報告結果僅對測試之樣品負責
 未經本公司事先書面同意, 此報告不可部分複製

試驗結果:

| 試驗項目 | 試驗方法 | 試驗結果 |
|----------------------------|-----------------------------------|-----------|
| 附著強度(kgf/cm ²) | ASTM D4541-17 Method E, Type V | 106.4 |
| 密著性(1 mm) | CNS 10757(1995) | 10 點(無剝離) |
| 耐屈曲($\phi=5$ mm, 180°) | | 無龜裂、無剝離 |

註: 1. 試驗樣品為單液型。
 2. 試驗試片製作依委託單位指定, 刷塗2道, 每道間隔1小時, 再放置常溫乾燥7天。
 3. 本試驗報告附著強度試驗非 TAF 認證範圍, 其餘則是。

----- oOo -----

本報告若有提供規範值, 該規範值僅供參考, 合格之判定以委託單位實際要求為準



報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction clauses defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.



材料及工程實驗室-高雄

試驗報告



報告編號：KK-18-06904

頁數：1 OF 1

報告日期：107年08月06日

委託單位：無機善護宅有限公司
 地址：高雄市前鎮區佛南街139號
 產品名稱：金鎧甲 SJ 特殊金屬奈米防鏽封閉塗劑
 產品顏色：淺藍色
 供應廠商：無機善護宅有限公司
 送驗廠商：無機善護宅有限公司
 收件日期：107年07月24日
 試驗日期：107年07月24日~107年08月03日
 試驗方法：萬能試驗機
 備註：1.以上資料由顧客提供(收件及試驗日期除外)
 2.除非另有說明，此報告結果僅對測試之樣品負責
 未經本公司事先書面同意，此報告不可部分複製


=====
試驗結果：

| 項目 \ 試件編號 | #6 鋼筋 (表面有防銹塗劑) | #6 鋼筋 (表面無防銹塗劑) |
|-----------|--------------------|--------------------|
| 抗拉荷重(kgf) | 10771 | 2333 |
| 破壞情形 | 混凝土破裂 | 鋼筋拔出 |

| 項目 \ 試件編號 | #6 鋼筋(表面有防銹塗劑) / #6 鋼筋(表面無防銹塗劑) |
|-----------|---------------------------------|
| 強度比(%) | 460 |

----- oOo -----

本報告若有提供規範值，該規範值僅供參考，合格之判定以委託單位實際要求為準


 報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

TWC4807308

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No.61, Kai-Fa Road, Nanzih Export Processing Zone, Kaohsiung, Taiwan / 高雄市楠梓加工出口區開發路61號
t (886-7) 301-2121 f (886-7) 301-1165 www.sgs.tw

Member of SGS Group

cecily_lin

2007



